

LISTING INFORMATION

Manufacturer: Yamatake Corporation		Customer ID: 1000003046	
Distributor/Private Labeler: Honeywell S.A.		Project ID: 3023333	
TYPE OF LISTING: (Check all that apply)		Class Number: 3610	
<input checked="" type="checkbox"/> New Client/New Listing	<input checked="" type="checkbox"/> Addition to Client's listing	File Name: 3023333bab	
<input type="checkbox"/> Revised (changes all of listing)	<input type="checkbox"/> Name Change (Company)	Address Change (Approval Guide Address)	
EQUIPMENT CLASSIFICATION (Book, Chapter, Section): Electrical, Hazardous Locations, Chapter 2			
COMPANY NAME (As it appears in the guide) Honeywell S.A.		ADDRESS (As it appears in the guide) Avenue du Bourget 3 B-1140 Brussels BELGIUM	

Provide listing below. Use red font for additions, strikethroughs for deletions.

Please add the following products to Honeywell S.A.'s new listing in the Approval Guide:

Model MGG17D-abcde5fgh-ij-k, Magnew 3000 Flowmeter Detector.

XP-IS-DIP/I,II,III/1/BCDEFG/* Ta = 60°C; - 80390309;TYPE 4X

a = Flowmeter size 002, 005, 010, 015, 025, 040, 050, 065, 080, 100, 125, 150 or 200

b = Lining E, P or Q

c = Type/Flange rating 11, 12, 13, 14, 15, 21, 22, 31, 41, 42, 43, 44, 45, 61 or 62

d = Electrodes A, B, C, D, E, F, H, J, K, L, M, N, P, S, T or W

e = Ground rings A - Z

f = Face to face length A - Z

g = Wiring direction A, B, C or D

h = Calibration A - Z

i = Finish 1, 2, 3, 4, 5 or X

j = Bolts/Nuts 1, 2, or X

k = Options not affecting safety A, B, C, D, E, F, G, H, J, K, L, M, P, R, S, W, X, and Y (one or more)

* Refer to Drawing 80390309 for T-code

Model MGG17F-abcdef5ghi-j-k, Magnew 3000 Detector.

XP-IS-DIP/I,II,III/1/BCDEFG/* Ta = 60°C; - 80390309;TYPE 4X

a = Flowmeter size 002, 005, 010, 015, 025, 040, 050, 065, 080, 100, 125, 150, 200, 250, 300, 350 or 400

b = Lining E, P, Q or R

c = Type/Flange rating J1, J2, J3, J4, J5, J6, A1, A2, G1, D1, D2, D3, D4, D5 or D6

d = Flange material 1, 2, 3 or 4

e = Electrodes A, B, C, D, E, F, H, J, K, L, M, N, P, S, T or W

f = Ground rings A - Z

g = Face to face length A - Z

h = Wiring direction A, B, C or D

i = Calibration A - Z

j = Finish 1, 2, 3, 4, 5 or X

k = Options not affecting safety A, B, C, D, E, F, G, H, J, K, L, M, P, R, S, W, X, and Y (one or more)

* Refer to Drawing 80390309 for T-code

Model MGG17U-abcde5Afg-h-i, Magnew 3000 Flowmeter Detector.

XP-IS-DIP/I.II.III/I/BCDEFG/* Ta = 60°C; - 80390309;TYPE 4X

a = Flowmeter size 002, 005, 010 or 015

b = Lining E, P or Q

c = Type/Flange rating U1, U2, U3, U4, H1, C1 or C2

d = Electrodes A, B, C, D, E, F, H, J, K, L, M, N, P, S, T or W

e = Ground rings A - Z

f = Wiring direction A, B, C or D

g = Calibration A - Z

h = Finish 1, 2, 3, 4, 5 or X

i = Options not affecting safety A, B, C, D, E, F, G, H, J, K, L, M, P, R, S, W, X, and Y (one or more)

* Refer to Drawing 80390309 for T-code

ORIGINATOR Brad Bombardier <i>Brad Bombardier</i>	DATE 3/22/05	REVIEWED BY <i>J. W. Lyons</i>	DATE 3/23/05
FOR ADMINISTRATIVE USE ONLY			
AGREEMENT RECEIVED BY		DATE	
FOR AG OFFICE USE ONLY			
DATE RECEIVED _____	CHECKED IN PS _____	CHECKED IN ACCESS _____	CHAPTER & PAGE # _____