

MagneW 3000 PLUS FOUNDATION Fieldbus

Issued : Oct. 31, 2001	Page : 2-12 (F)
Effective : Oct. 1, 2002	UNIT : 1000YEN

Converter

MGG14C-I II III IV-V VI VII VIII- YH/Options (some options can be selected per each model.) **Fieldbus**

Price is the sum of the price of all selections made.

Option "Y" must be specified.

Option "H" must be specified for **Indication other than SI units**.

Lead-time: after receipt of order(s), ex-factory basis

				Basic price	Lead time (wk)
MGG14C-				315	2
				Additional price	
I	Power supply	AC100V 50/60Hz	A		
		AC110V 50/60Hz	B		
		AC115/120V 50/60Hz	C		
		AC200V 50/60Hz	D		
		AC220V 50/60Hz	E		
		AC230/240V 50/60Hz	F		
		DC24V AC Noise filter 50Hz	G		
		DC24V AC Noise filter 60Hz	H		
II	Output signal/communication	FOUNDATION Fieldbus	F	110	
III	Conduit connection/ Watertight gland	G1/2 internal thread/without watertight gland	1	0	
		G1/2 internal thread/with brass(Ni-plated) watertight gland	2	10	
		G1/2 internal thread/with plastic watertight gland	3	5	
		1/2 NPT internal thread/without watertight gland	4	0	
		CM20 internal thread/without watertight gland	5	0	
		Pg13.5 internal thread/without watertight gland	6	0	
		G1/2 internal thread/with SUS304 watertight gland	7	15	
IV	Installation/ Wiring direction	Integral type	Horizontal piping mounting/Upstream side	A	0
			Horizontal piping mounting/Downstream side	B	0
			Horizontal piping mounting/Left side viewed from upstream	C	0
			Horizontal piping mounting/Right side viewed from upstream	D	0
		Remote type	Vertical piping mounting/Downstream side	E	0
			Vertical piping mounting/Downstream side	F	0
			Wall mounting with standard bracket	G	0
			2in. pipe mounting with standard	H	0
				-	
V	Finish	Standard	X	0	
		Corrosion-resistant finish	1	5	
		Corrosion-proof finish	2	10	
VI	Display	None	X	0	
		with display	A	40	
VII	Contact inputs/outputs	None	X	0	
VIII	Style code	None	X	0	

Options	Must be selected	Y	Additional price	
	Empty pipe detection function	A	0	
	Traceability certificate	C	10	
	Indication other than SI units (Must be selected)	H	0	6
	Attachment of the TAG number to the terminal box <small>Note 1</small>	J	4	6
	Specific color finish <small>Note 2</small>	L	40	6

Note 1: Must be selected for Tag No. requirement.

Note 2: Must specify Munsell No.