

**MODEL SELECTION**

Issued: Jul. 1, 2008	Page: 1-0-10
Effective: Dec. 1, 2011	UNIT: 1000YEN

**Model GTX30A(Standard absolute pressure)**  
**Model GTX60A(High absolute pressure)**

**Model No.:GTX A-Selection I (I II III IV V VI VII)-Selection II (I II III IV V VI)-Option**

Basic Model No.

Measuring span	4.0 to 104kPa abs. (30 to 780mmHg)*5	GTX30A
	35 to 3500kPa abs. (0.35 to 35kgf/cm <sup>2</sup> )*6	GTX60A

<b>Basic price</b>
400

Selection I

I	Output	4 to 20mA (SFN Communication)	A
		4 to 20mA (HART Communication)	B
		Digital output(DE communication)*12	D
II	Fill Fluid	Regular type (Silicone oil)	A
		For oxygen service (Fluorine oil)	H
		For chlorine service(Fluorine oil) *11	J
III	Material (Meterbody cover/Vent/Drain)	Meterbody cover	Vent / Drain plugs
		SCS14A	316.SST
		PVC *1*2*3*4*13	PVC *1*2*3*4*13
IV	Material	316 SST (Diaphragm:316L SST)*9	A
		ASTM B575 (Equivalent to Hastelloy C-276)*7*10	B
		Tantalum *7*10	C
		316L SST*7*10	D
V	Process connections	Rc 1/2, with adapter flange*3	A
		Rc 1/4, with adapter flange	B
		Rc 1/4, without adapter flange	C
		1/2 NPT internal thread, with adapter flange*3	D
		1/4 NPT internal thread, with adapter flange	E
		1/4 NPT internal thread, without adapter flange	F
VI	Process installation	Vertical piping, top connection*4*7	A
		Vertical piping, bottom connection*4*7	B
		Horizontal piping, front connection	C
VII	Bolt/nut	Carbon steel	A
		304 SST	B
		630 SST	C

<b>Additional price</b>
0
5
0
0
18
18
0
20
0
36
77
77
3
3
0
3
3
0
0
0
0
0
11
35

Selection II

I	Electrical connections	1/2 NPT, Watertight	A
		M20, Watertight *8	B
II	Explosion proof	None	XX
		FM Explosionproof	F1
		FM Intrinsically safe	F2
		FM Nonincendive	F5
		Combined of FM Explosionproof, Intrinsically safe and Nonincendive	F6
		ATEX Explosionproof	A1
		ATEX Intrinsically safe	A2
		ATEX Type n	A5
		IECEx Explosionproof	E1
		IECEx Intrinsically safe	E2
		IECEx Type n	E5
		NEPSI Explosionproof	N1
		NEPSI Intrinsically safe	N2
NEPSI Type n	N5		
III	Indicator	None	X
		With indicator	A
IV	Paint	Standard	X
		Corrosion-proof (Urethane)	H
		Corrosion-resistant (Silver color)	D
V	Failure alarm	UP Scale	A
		DOWN scale	B
VI	Mounting bracket	None	X
		CF8 (L form)*9	1
		Carbon steel (L form)*9	3
		SUS304 (L form)*9	4
		Carbon steel (Flat form)*10	5
		SUS304 (Flat form)*10	6

0
5
0
8
8
8
8
8
8
8
8
8
8
8
0
20
0
14
16
0
0
0
12
2
30
2
10

Note)

- \*1 304 SST bolts and nuts material (-B) must be selected when PVC meterbody cover is selected (-C).The max. working pressure is 1.5MPa.
- \*2 Applicable for wetted parts of center body material ;ASTM B575 or Tantalum
- \*3 In case PVC is selected, code A, or D of Process connections should be selected.
- \*4 In case PVC is selected, code A, or B of Process installation should be selected.
- \*5 Specify range in abs. Pressure. Correct: 0 to 500mmHg abs. Incorrect: -700mmHg to 1kgf/cm<sup>2</sup>
- \*6 Specify range in abs. Pressure. Correct: 0 to 3kgf/cm<sup>2</sup> abs. Incorrect: -1 to 2kgf/cm<sup>2</sup> abs.
- \*7 Code A, or B of Process installation should be selected.
- \*8 Not applicable for the combination with code F1and F6 of Explosion proof.
- \*9 Applicable for wetted parts of material (centerbody) ;316 SST
- \*10 Applicable for wetted parts of material (center body) ;ASTM B575,Tantalum, and 316L SST
- \*11 In case code J is selected, code C "Tantalum" of Material(centerbody) should be selected.
- \*12 Not applicable for the combination with code A2 "With external Zero/Span adjustment", Q1 "Safety Transmitter", and Q2 "NAMUR NE43 Compliant Output signal limits" of Option.
- \*13 In case PVC is selected, Not applicable for the combination with code T2"Mill certificate" of Option code.

Model No.:GTX\_\_A-Selection I (I II III IV V VI VII)-Selection II (I II III IV V VI)-Option

Option		Additional prices
XX	No options	0
A2	With external Zero/Span adjustment*11*16	30
G1	One elbow (left)*6*7*10	2
G2	One elbow (right)*6*10	2
G3	2 elbows*6*8*10	4
G4	Long vent/drain plugs	5
G6	Side vent/drain top*6	4
G7	Side vent/drain bottom*6	4
K1	Oil and water free finish	17
K3	Oil free finish*4	10
Q1	Safety Transmitter*5*16	0
Q2	NAMUR NE43 Compliant Output signal limits:3.8 to 20.5mA (Output 21.6mA/selected upper limit, 3.6mA/selected lower limit)*16	20
Q7	Alarm Output(contact output)*17	10
R1	Custom calibration	5
T1	Test report	2
T2	Mill certificate	21
T4	Traceability certificate	10
T5	NACE certificate*9	5
W1	Non SI Unit	0

\*4 No need to select when Fill Fluid code H, or J is selected.

\*5 Not applicable for the combination with code A2, or Q7 of Option

\*6 Not applicable for the combination with code A, or B of Process installation.

\*7 Not applicable for the combination with code F1,F6 of Explosion proof.

\*8 Not applicable for any Explosion proof. Please select code XX "None" of Explosion proof.

\*9 Applicable for "ASTM B575", code B of Material (center body).

\*10 Not applicable for the combination with code B "M20 watertight" of Electrical connection.

\*11 Not applicable for the combination with code X "None" of Indicator. Please select "With indicator".

\*16 Not applicable for the combination with code D "Digital output(DE communication)" of output

\*17 Not applicable for the combination with code F2,F5,F6,N2,N5,E2,E5,A2 and A5 of Explosion proof.