

Explosion proof model

Basic Model No.		table1	table2	Option	List Price
ATT70					
Output	Analog (4 -20mA)	A			98
	Digital (DE -protocol)	D			98
	Analog output with HART ^R	H			103
Safety Approval	TIIS Flameproof	2			22
	FM Exprosn proof	4			22
Electrical connection	G1 / 2 *1	1			0
	1 / 2NPT *2	2			0
Integral digital meter	Without		X		0
	LCD meter for deg. C *3		M		20
	LCD meter for deg. F *3		F		20
Finish	Standard finish		S		0
	Corrosion -resistant finish		A		7
	Corrosion -proof finish		B		10
Burnout feature	Upscale			U	0
	Downscale			D	0
Options *4	No selection			X	0
	Certificate of traceability			A	10
	Mounting bracket			B	15
	Customer configurations(sensor type and measuring range) *5			C	5
	Two elbows for electrical conduits *6			F	10
	Calibration test report			T	2

- note:
- *1 Only applicable for TIIS Flameproof "code 2" in the Safety Approval.
 - *2 Only applicable for FM Exprosn proof "code 4" in the Safety Approval.
 - *3 If sensor type is [mV], Engineering unit is displayed in [mV].
 - *4 Up to five options may be selected simultaneously.
 - *5 If it is required to configure sensor type, range and tag No. at the ex factory, please select "C" and specified specifications separately. If there is no specified specification, the unit will be configured with the default value.
 - *6 Only applicable for the G1/2 "code 1" in the Electrical connection.