

NOT to be distributed outside the FACTORY MUTUAL SYSTEM, except by CLIENT.

# APPROVAL REPORT

Yamatake Corporation


Shonan Factory

**ADVANCED TEMPERATURE TRANSMITTER  
MODELS ATT70 AND ATT71  
SENSOR MODELS ATT81 AND ATT82  
FOR HAZARDOUS (CLASSIFIED) LOCATIONS**

**Prepared For:**

**Yamatake Corporation  
Shonan Factory  
4-1-1 Omagari, Samukawa-machi  
Koza-gun, Kanagawa-ken 253-0113  
Japan**

**J.I. 3003925  
(3615)  
July 19, 1999**

**FACTORY MUTUAL | **

1151 Boston-Providence Turnpike  
P.O. Box 9102  
Norwood, Massachusetts 02062

52-1/4

Factory Mutual Research Corporation  
1151 Boston-Providence Turnpike  
P.O. Box 9102  
Norwood, Massachusetts 02062

J. I. 3003925  
(3615)

July 19, 1999

**ADVANCED TEMPERATURE TRANSMITTER  
MODELS ATT70 AND ATT71  
SENSOR MODELS ATT81 AND ATT82  
FOR  
HAZARDOUS (CLASSIFIED) LOCATIONS  
from  
Yamatake Corporation  
Shonan Factory  
4-1-1 Omagari, Samukawa-machi  
Koza-gun, Kanagawa-ken 253-0113  
Japan**

## I INTRODUCTION

1.1 Yamatake Corporation (manufacturer) requested Factory Mutual Research Corporation (FMRC) Approval of their Models ATT70 and ATT71 Advanced Temperature Transmitter (ATT) and Models ATT81 and ATT82 Sensors as explosionproof for Class I, Division 1, Groups A, B, C and D; flameproof for Class I, Zone 1 AEx d IIC T<sub>6</sub>; dust-ignitionproof for Class II/III, Division 1, Groups E, F and G hazardous (classified) locations; indoor/outdoor (NEMA Type 4X).

1.2 The specific models described by this report will be listed in the FMRC Approval Guide as follows:

***ATT7a-b4c-def-g. Advanced Temperature Transmitter.***

XP/II/1/ABCD/T6 Ta<80°C; I/1/AEx d IIC/T6 Ta<80°C; DIP/II,III/1/EFG/T6 Ta<80°C; Type 4X

a = Type 0 or 1.

b = Output/Communication Protocol A, D, H or F.

c = Conduit connection 2 or 6.

d = Indicator X, F, G, H, J, M, N, P or Q.

e = Paint S, A, B, D or F.

f = Burnout feature X, U or D.

g = Option X, A, B, C, D, E, F, G, H, J, L, R, S, T, U, V or W.

**ATT81-ab-cdeX-f. Sensor for Model ATT71 Advanced Temperature Transmitter.**

XP/I/1/ABCD/T6 Ta<80°C; I/1/AEx d IIC/T6 Ta<80°C; DIP/II,III/1/EFG/T6 Ta<80°C; Type 4X

- a = Sensor type B, E, J, K, N, R, S, T, P or Q.
- b = Sensor length in mm (100-900).
- c = Thermal well stem style A or B.
- d = Thermal well material 1, 2 or 3.
- e = Thermal well mounting thread size A, B, C, G, H, J, N, P or Q.
- f = Option X, A, B, C, D, E, F, G, H, J, K, L, M, or P.

**ATT82-ab-cdef-g. Sensor for Model ATT71 Advanced Temperature Transmitter.**

XP/I/1/ABCD/T6 Ta<80°C; I/1/AEx d IIC/T6 Ta<80°C; DIP/II,III/1/EFG/T6 Ta<80°C; Type 4X

- a = Sensor type B, E, J, K, N, R, S, T, P or Q.
- b = Sensor length in mm (100-900).
- c = Thermal well stem style A or B.
- d = Thermal well material 1, 2 or 3.
- e = Thermal well mounting flange pressure A, B, C, D, E, G, H, J, K, L, M, N, P, Q, R, S or T.
- f = Thermal well mounting flange size 1, 2, 3, 4, 5, 6, 7, 8 or 9.
- g = Option X, A, B, C, D, E, F, G, H, J, K, L, M or P.

1.3 Approval of the subject equipment is based on the applicable requirements of the following standards.


| <u>TITLE</u>   | <u>AUTHOR-NUMBER</u>                  | <u>DATE</u>    |
|--|---------------------------------------|----------------|
| Electrical Equipment For Use In Hazardous (Classified) Locations General Requirements                                | FMRC-3600                             | 1998           |
| Explosionproof Electrical Equipment  | FMRC-3615                             | 1989           |
| Electrical Apparatus for Use in Class I, Zones 0 & 1 Hazardous Classified Locations General Requirements             | ANSI/ISA-S12.0.01                     | 1998           |
| Electrical Apparatus for Use in Class I, Zone 1 Hazardous (Classified) Locations Type of Protection - Flameproof "d" | ANSI/ISA-S12.22.01                    | 1998           |
| Electrical and Electronic Test, Measuring and Process Control Equipment  | FMRC-3810<br>(Including Supplement 1) | 1989<br>(1995) |
| Enclosures For Electrical Equipment  | ANSI/NEMA-250                         | 1991           |

1.4 As described in this report, the construction of these units provides the degree of protection against Electrical shock, fire, and injury required for hazardous (classified) locations.


FACTORY MUTUAL RESEARCH CORPORATION

FMRC J.I. 3003925

REPORT BY:

  
Edmond W. LaLiberte  
Project Engineer, Electrical Section

REPORT REVIEWED BY:

  
R. P. Lutfy  
Electrical Section Manager